

DISCFLO Pump

Partial User's List



<u>End User</u>	<u>Contact</u>	<u>Phone #</u>	<u>Position</u>	4/1/2007 <u>Application</u>	<u>Pump Model</u>	<u>Years</u>
City of Cocoa - FL Engr - CDM	Gary Heller gheller@cityofwinterpark.org (Gary recently took position at Winter Park)	407-599-3538	Div Chief Water & WW	60-70% Lime Sludge	(4) 403-14-2HHD	15 yrs.
			Cocoa has not had to change casings or discpacs on the DISCFLO pumps in 13 YEARS! Previously they had to rebuild their Moyno progressive cavity pumps every 3-4 months.			
	Carl Larrabee, PE clarrabee@cocoa.org	321- 639-7651	Director of Utilities			
Engr - CH2M Hill	Troy Howell thowell@cocoaf1.org	321-635-7770	Plant Super.	Belt filter Press Feed	(3) 302-10-2HHD	9 yrs.
				Lime Slurry transfer	(2) 402-12-2HHD	8 yrs.
City of Boca Raton - FL Engr - City	Greg Essen gessen@ci.boca-raton.fl.us	561-338-7323	Chief Oper.	45% Lime Sludge	(2) 604-14-2HHD	14 yrs.
			Pump has performed extremely well with ZERO MAINTNENANCE. Replaced (3) Neutz progressive pumps which were rebuilt every year			
City of Fort Myers - FL Engr - Black&Veatch	Kevin Wagner	941-332-6871	Oper. Mgr.	2% WW sludge-BFP Feed	(6) 604-14-2HHD	9 yrs.
			Replaced (6) MonoLobe pumps. DISCFLO has performed great. They are feeding belt filter presses.			
City of Coral Springs Engr - CDM	Dave Moore	954-345-2161	Chief Oper.	45% Lime Sludge	(4) 403-14-2HHD	9 yrs.
	Charlie Lindsay (Retired)		DISCFLO is performing excellently and Coral Springs has not replaced any pump parts			
Denver Metro WW Dist. Denver, CO Engr - Black&Veatch Engr - CH2M Hill	Mike Carver, PE mcarver@mwrddst.co.us	303-286-3229	City Engineer	Anaerobic Sludge Recirculation	(10) 604-14-2HHD	14 yrs.
				Centrifuge Feed	(4) 604-14-2HHD	4 yrs
				Centrate Transfer	(7) 604-14-3HHD	
	Sherman Papke, PE spapke@mwrddst.co.us	303-286-3229	Div Head, Treatment Plnt	Acid Sludge Transfer	(3) 806-17-2HHD	
				Sludge Recirculation	(2) 604-14-2HHD	
				Digester Effluent	(2) 806-14-2HHD	
	John Powers	303-286-3383	Maint. Mgr.			

<u>End User</u>	<u>Contact</u>	<u>Phone #</u>	<u>Position</u>	<u>Application</u>	<u>Pump Model</u>	<u>Years</u>
Gainesville Reg. Utilities Gainesville, FL Engr - CH2M Hill	Rick Davis	352-334-2867	Plant Superintendent	45% Lime Sludge	(2) 403-14-2HHD	11 yrs.
			Discflo replaced two styles of pumps in this abrassive application, Moyno progressive cavity and air operated diaphram. Both of these pumps were very high maintenance. The Discflo pumps have required zero maintenace since installation in 1998.			
				45% Lime Sludge	(2) 403-14-2HHD	3 yrs.
			Duplicated original pumps with two more on an expansion			
				10% Lime Slurry	(6) 2015-8-2HHD	
			Replaced high maintenance cantilever pumps on expansion project			
Johnson County W.W. District - Kansas, KS	Mary Pegg	913-432-3820	Plant Superintendent	Primary Sludge	(4) 604-14-2HHD	19 yrs.
			The Discflo pumps have very low maintenance for this difficult application. Mary says the pumps have been great for her 100% primary sludge application.			
Kiehi WWTP	Clarence Solomon	808-879-2771	As. Superintendant	Waste Water Grit	(3) 403-14-2D	19 yrs.
			These 3 pumps in Maui have been in service for about 18 years or longer and have not had any significant maintenance problems. Clarence is very pleased with the Discflo pumps.			
City of Apopka - FL Engr - City Engr - Boyle	Tim Moyer Al Fisher AFisher@apopka.net	407-703-1746 407-703-1782	Chief Operator	BFP Feed Pump	(2) 403-12-2HHD	6 yr.
			Replaced high maintenance lobe pump.			

<u>End User</u>	<u>Contact</u>	<u>Phone #</u>	<u>Position</u>	<u>Application</u>	<u>Pump Model</u>	<u>Years</u>
City of Ormond Beach, FL Engr - CDM	Colin Hobbs, PhD hobbscm@cdm.com	(407) 660-2552	Consulting Engineer	30-45% Lime Sludge - Centrifuge Feed	(3) 302-10-2HHD	6 yr.
Coral Springs Improvement District (CSID) - FL Engr - Jones Edmunds	Doug Hyche jhyche@msn.com	954.796.6617	Operations Superintendent	10% Lime Slurry	(3) 302-10-2HHD	6 yr.
South Central Regional WRF - Delray Beach, FL Engr - CDM	Dennis Coates dcoates@scrwwtp.org	561.272.7061	Director of Operations	10% Lime Slurry	(1) 2015-2HHD	9 yr.
Veolia (Montenay Power) Miami, FL	Dwight Beatty dbeatty@montenay-onyx.com	305.593.7167	Maintenance Mgr.	10% Lime Slurry w/GAC	(4) 201-14-2HHD 50 GPM @ 200 PSI	6 yr.
				Replaced 12 PD pumps that req'd 15 new pumps/yr to maintain the 12 units in service		
				20% Lime Slurry	(2) 302-10-2HHD	5 yr.
City of Titusville, FL Engr - City	Bill Grubb bill.grubb@titusville.com	321.383.5658	Chief Maintenance Mechanic	45% Lime Sludge	(1) 2015-8-2HHD (1) 402-14-2HHD (2) 403-12-2HHD	10 yrs. 6 yrs. 2 yrs.
				Bill replaced high maintenance progressive cavity pumps for Lime Sludge load-out Original 2015-2HHD pump retired from service after 10 yrs with no pump parts replacements needed		
Rocky Mount, NC Tar River Regional WWTP	Dennis Carpenter dennis.carpenter@rockymountnc.org	252.972.1402	Treatment Plant Lead Mechanic	Scum Transfer	(2) 604-14-2D	15 yrs.

<u>End User</u>	<u>Contact</u>	<u>Phone #</u>	<u>Position</u>	<u>Application</u>	<u>Pump Model</u>	<u>Years</u>
Newton County, GA Engr - JJG	Kevin Miller kmiller@co.newton.ga.us	770.786.1414	Wastewater Superintendent	4% Sludge - Centrifuge Feed	(3) 403-12-2HHD	1 yr.
Cobb County Marietta Water Authority - Kennesaw, GA Engr - City	Lamar Hunt lhunt@ccmwa.org	770.974.4286	Operations Supervisor	Alum Sludge w/Lime Plate & Frame Press Feed	(2) 604-17-2HHD	2 yrs.
	Patrick Pherson ppherson@ccmwa.org	770.426.8788	Project Engineer			